

Comments Submitted by S. Gabel, Honeywell

| 16-Aug-2010 | | | |
|--|--|--|--|
| Honeywell comments to NAESB REQ PAP10 Business Practices and Information Model Recommendation "smart_grid_pap10_081010reqcom_a2.doc" | | | |
| line | text | comment | proposed |
| | (various lines in the NAESB document) | Honeywell supports the comments and proposed resolutions made by the EIS Alliance, as submitted by David Bunzel on 8/16/2010 | |
| 114 | "Usage and load information shall be readily available" | intent is "overall" usage and load | add the term "overall" |
| 122 | "definition of real-time and near real-time " | something on the order of seconds is expected | add a spec for a range in seconds |
| 229 | "information outlined within the model should be available." | All the informational elements may not be applicable to all premises | Each information element should be designated as mandatory or optional |
| 296-301 | Energy Management System (EMS) | the definition offered seems oriented toward residential only | expand the definition to address C&I |